

State Water Resources Control Board

June 12, 2018

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7017 2680 0000 6195 8978

Ms. Beth DePaola
Associate Business Management Analyst
California Highway Patrol
P.O. Box 942898
Sacramento, California 94298-0001
edepaola@chp.ca.gov

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS
LOCATED AT CALIFORNIA HIGHWAY PATROL – YUBA SUTTER AREA,
1619 POOLE BOULEVARD, YUBA CITY**

Dear Ms. DePaola:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST at your facility on May 24, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Tag Monitoring Equipment – The monitoring panel was missing the annual monitoring certification tag for the most recent monitoring system certification performed on May 23, 2017.	Unleaded	May 24, 2018	Ongoing	23 CCR 2638(f)
2	Failure to Maintain Monitoring Plan – In CERS, the tank monitoring, pipe monitoring, and under dispenser containment (UDC) monitoring sections are missing the sensor model numbers, and the line leak detector manufacturer and model number.	Unleaded	May 24, 2018	Ongoing	H&SC 25286(a); 23 CCR 2632(d)(1) and 2711(a)(9)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Sutter County Environmental Health Services within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Mr. Will Speth
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
will.speth@waterboards.ca.gov

Local CUPA

Mr. Sukh Sahota R.E.H.S, Supervisor
Sutter County Environmental Health Service
1130 Civic Center, Suite A
Yuba City, California 95993
ssahota@co.sutter.ca.us

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: (via email only)

Mr. Sukh Sahota, R.E.H.S, Supervisor
Sutter County Environmental Health Service
ssahota@co.sutter.ca.us

Mr. Thomas Rockenstein
Automotive Technician
California Highway Patrol
trockenstein@chp.ca.gov